



Certificate of Compliance

Certificate: 80054085

Master Contract: 167018

Project: 80058825

Date Issued: 2020-10-22

Issued To: Sensia
7000 Nix Dr
Duncan, Oklahoma, 73533
United States

Attention: Kathy M. Metzger

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Lucas Nieuwenhout
Lucas Nieuwenhout

PRODUCTS

CLASS - C225206 - PROCESS CONTROL EQUIPMENT PROCESS CONTROL EQUIPMENT

CLASS - C225286 - PROCESS CONTROL EQUIPMENT Certified to US Standards

Stand-alone flow computer, Scanner 3300 EFM, rated 9-30VDC, 1.4A max.

Notes:

1. The above model is permanently connected, Equipment Class III, Pollution Degree 3, Overvoltage Category I.
2. Mode of operation: Continuous
3. Environmental Conditions: -10°C to +60°C, 2000 m max, 95% RH
4. The certified device is a component, which are intended for use in other equipment where the suitability of the combination is to be determined in the end use application.



Certificate: 80054085
Project: 80058825

Master Contract: 167018
Date Issued: 2020-10-22

APPLICABLE REQUIREMENTS

CSA CAN/CSA-C22.2 NO. 61010-1-12, UPD1:2015, UPD2:2016 - Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements - Third Edition

UL Std. No. 61010-1 3rd Edition (2016) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirement – Third edition



Supplement to Certificate of Compliance

Certificate: 80054085

Master Contract: 167018

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80058825	2020-10-22	Report reissued to add Classes 2252 06 and 2252 86 to CRIS. No changes were made to the product.
80054085	2020-09-25	Stand-alone flow computer, Scanner 3300 EFM